RESIDENTIAL GATE LOCK STANDARDS FOR NON-DESTRUCTIVE EMERGENCY FIRE ACCESS.

The standard safety measure that allows for expedient Fire Department access to your property is to use a Knox device. Knox is a company that provides secure products that allow Emergency Responders to use a standard key to access the property. Those products range from electronic switches to padlocks to secure lock boxes that can only be opened by a secured Fire Department Key. This is a guide to choose the correct device for a gate on your property.

Manual Gates

Knox Padlock with Multi-Locking Device

The property owner will be unable to open the Knox Pad Lock. It will need to be installed with a multi-locking device that is used appropriately so that the gate can be fully opened if either of the pad locks is removed

Electronic Gates

Knox Key Switch

The Knox key Switch should be installed near headlight level and is usually mounted on the arm of the keypad. For installation, refer to the gate or fencing company that installed the gate.

Ordering Instructions for Knox Pad Lock to be installed on a Manual Gate:

Go to www.**knoxbox.com**

On the top left hand side of the page there should be a section that says "**START HERE TO PLACE AND ORDER.**" Click on the text.

In the pop-up window enter the "**installation address**" and select "**Set Address**". Confirm the address in the following window.

In the next pop up window, select the correct fire department: "**Clark-Cowlitz Fire Rescue (WA)**" and confirm the department. If "**Clark-Cowlitz Fire Rescue (WA)**" doesn't show up, click "**Search For Your Department**" and enter "**Clark-Cowlitz Fire Rescue**".

Scroll down and click on "**KNOX PADLOCKS**".

FOR A PADLOCK (*Manual Gates*): select the first group for **All Weather Locks**; then the select "**Standard**" or the "**Long**" depending on the space and orientation of your gate.

- A Mult-Locking Device is also required, we would recommend "**Gate Keeper Locks**". For a two Padlock configurations the "**GM-ELEC01 Electrical Panel Gate Lock**", for more than two Padlocks, any of the other devices will also work.

Once you fill out the order information, your order request will be sent to CCFR's Fire Marshal's office for approval.

Remember a multi-locking device shall be purchased. No specific brand is required, although we have seen the ease of the "Gate Keeper Lock" devices.

Once your Knox pad lock has been locked, it cannot be opened by anyone but Fire Department. When you receive your pad lock it will be in the locked position, you will need to call CCFR to schedule a time to lock it on your gate.

For any questions call CCFR at 360-887-1684

Ordering Instructions for Knox Key Switch installed on an Electronic Gate:

Go to www.**knoxbox.com**

On the top left hand side of the page there should be a section that says "**START HERE TO PLACE AND ORDER.**" Click on the text.

In the pop-up window enter the "**installation address**" and select "**Set Address**". Confirm the address in the following window.

In the next pop up window, select the correct fire department: "**Clark-Cowlitz Fire Rescue (WA)**" and confirm the department. If "**Clark-Cowlitz Fire Rescue (WA)**" doesn't show up, click "**Search For Your Department**" and enter "**Clark-Cowlitz Fire Rescue**".

Scroll down and click on "**KNOX GATE AND KEY SWITCHES**.

FOR A KEY SWITCH (*Electronic Gates*): Select "**Single Mechanical Lock on Mounting Plate**" "Switch Signal"
select **SPDT (One Signal per Lock)** Under "Signals"
select **One Signal per Lock (SPDT)**.

Once you fill out the order information, your order request will be sent to CCFR's Fire Marshal's office for approval.

Contact the Gate Company that installed the gate for installation.
For any questions call CCFR at 360-887-1684

Clark-Cowlitz
FIRE RESCUE